


Electric Service



If a Field Service Representative observes a potential **Unsafe Condition** at your location: **loose, rusted, or worn meter socket, or worn entrance cable** that is in need of replacement or repair. This is an unsafe condition for you as a homeowner as well as the public. In addition, **Meter Clearance from bushes, vines, fences, or storage items** must be rectified before service is energized.

- Customers should contact a **STATE LICENSED ELECTRICIAN OR APPROVED INSPECTION AGENCY** immediately upon notification of a potential unsafe condition. [*City Ordinance sec., 1-*



Customer Services
5 E Reed St, Dover, DE 19901
Tel: 302-736-7035
www.cityofdover.com/customer-services

CITY OF DOVER

Electrical Safety Inspection



Phone: 302-736-7035
Fax: 302-736-7193
E-mail: ebilling@dover.de.us

Electric Service Guidelines



A handy guide to Independent inspection companies licensed in Delaware that provide electrical inspections for safeguarding of lives and property.

The customer shall be responsible for all wire ways, weather heads, disconnects, entrance cable, conductors, meter sockets enclosures, connectors,

conduits, and all associated equipment.

The customer must allow access to any City property at any and all times.

In no case, will a locking device be installed by the customer to prevent access to meter sockets or City-owned equipment.

The use of jumpers is forbidden.

A minimum horizontal clearance of three feet must be provided in front of the meter socket/enclosure.

Delaware State Approved Inspection Companies

American Inspection Agency, Inc. 302-292-2000
1111 Polly Drummond Office Park 302-732-6900
Newark, DE 19711
www.americaninspectionagency.com

Building Inspection Underwriters, Inc. 800-732-2551
Liberty Plaza, Suite 1-C 302-266-9057
Newark, DE 19711
www.biuinc.com

Eagle Inspection Agency, LLC 302-368-1312
57 Mathews Road 302-379-3635
Newark, DE 19713-2555

First State Inspection Agency 800-468-7338
1001 Mattlind Way 302-422-3859
Milford, DE 19963
www.firststateinspection.com

Middle Department Inspection Agency 800-222-6342
11508 Commercial Lane Unit-D 302-999-0243
Laurel, DE 19956
www.mdia.net

United Inspection Agency 215-542-9977
180 S. Main St
Ambler, PA 19002

**** This list was the agencies available at the time of publication and only listed for information. Others may be available. ** Revised 10/27/15**

Tampering Prohibited

It is unlawful for any person, except a duly authorized representative of the City, to make any temporary or permanent connection or disconnection between the electric service load of the customer and electric service wire of the City.

This creates an unsafe condition for the homeowner, public, and City employee.

In the event that the City's meter or other property are tampered or interfered with, the customer being supplied through that equipment will be subject to tampering charges, fines, and/or arrest.

CITY OF DOVER ORDINANCE

City Ordinance [sec., 1-501]

All services that have been de-energized for more than **SIX** months shall be re-inspected prior to re-energizing.